



NOTE:

1. See City Plate No. WAT-01 for typical hydrant and gate valve layout.
2. See City Plate No. SER-01A for typical water service connection.
3. All water main shall be placed north and east of the center line of road.
4. All ductile iron water main fittings shall be fusion bonded epoxy coated.



STANDARD DETAILS
TYPICAL GATE VALVE LAYOUT

FARMINGTON, MINNESOTA

Last Revision:
FEB 2017

City Plate No.
WAT-07
2017